

Technical Data Sheet:	DS818-3
Product Description	Straight external swivel threaded, nickel plated brass for FSS
Product Range	FSS S Type fitting (Metric threads)



FLEXICON

FLEXIBLE CONDUIT SOLUTIONS

Roman Way, Coleshill
Birmingham
B46 1HG, United Kingdom
Tel: 00 44 (0)1675 466900
Website: www.flexicon.uk.com



FM58347



Material;
Nickel plated brass,
polyester conduit seal
and brass conduit clip

Colour:
Self coloured

Fire Performance:
Inherently low fire
hazard



IP Rating:



Applications:
•Suitable for knockout and threaded entries
•Multi part compression fitting for stainless steel corrugated conduit
•Provides high tensile strength and EMC screening

Temperature Performance:

-50 to +135°C

Conduit Size	Part No.	Metric Thread	Dimension (mm)					
			A	B	C	D	E	F (A/F)
16	FSS16-M16-S	M16 X 1.5	10.0	31.0	26.0	8.6	20.0	20.0
20	FSS20-M20-S	M20 X 1.5	10.0	32.0	29.0	15.0	26.0	26.0
25	FSS25-M25-S	M25 X 1.5	12.0	39.0	35.0	19.0	29.0	33.0
32	FSS32-M32-S	M32 X 1.5	13.0	44.0	42.0	26.0	38.0	40.0
40	FSS40-M40-S	M40 X 1.5	14.0	46.5	52.0	32.7	48.0	50.0
50	FSS50-M50-S	M50 X 1.5	15.0	50.0	58.0	38.0	58.0	58.0

A chemically blackened version of the conduit is available on request, part numbers FSS20B & FSS25B.

Black plated brass fitting also available on request.


Swivel fittings, internal threads and other sizes also available on request.

Compliance, Approvals & Accreditation;



EN 61386 Classification Available on request

Typical Applications;



Errors, omissions and amendments excepted. As part of continuing product development Flexicon Ltd reserve the right to alter product specifications without prior notice. Data given is correct at time of compilation. Product specification and application data is for guidance only and does not constitute a warranty of any kind, either expressed or implied for Flexicon products or their suitability for a specific purpose. Third party approvals maybe limited to certain sizes within a product range.

Created by; Sarah Lee - Marketing Assistant	Approved by; Alex Smith - Technical Director	Date; June 2019	Page Number; Page 1 of 1
---	--	---------------------------	------------------------------------