

Product Code:	Product Range:	Issue Date:
3M41025/3	3 Mod 4 Pole MCBs,Circuit Protective Devices,Four Pole MCBs,Industrial Products,Miniature Circuit Breakers	03/12/2025

Description:

25A 3 Mod 4P MCB 10kA C Curve

Features:

- Suitable for ABX, BX, XL, PX, OPBX, CBX, MCX, MX and PDU boards
- Thermal-Magnetic operation
- C Curve operating characteristics
- Mechanical Flag Indicator shows ON or OFF
- Operating dolly may be locked in either the ON or OFF position
- Contacts are manufactured from carefully chosen materials
- Selected for their low electrical resistance and low propensity to weld under fault conditions



Technical:

Height	113 mm
Width	54 mm
Depth	74 mm
Weight	0.556 Kg
Short circuit rating	10kA
Ambient temperature	-5 to +40 C
Mcb type	C Curve
Mounting	Din Rail
Guarantee	12 Months
Frequency	50 Hz
Cable entry	Box Terminals
Current rating	25A
Rated operated voltage	400 V
Incoming terminal capacity	25 mm
Number of modules	3
Packaging types	Each
Product range	Miniature Circuit Breakers 4P 10kA C Curve
Standards	BS EN 60898
Protection class ip rating	IP2X
Operating characteristics	C Curve
Material	Flame Retardant PA
Compliance	Low Voltage Directive 2014/35/EU
Manufacturer	Proteus Switchgear. Stafford Park 12. Telford. Shropshire. TF3 3BJ. United Kingdom.

Proteus Switchgear Website:

W: proteusswitchgear.co.uk

DECLARATION of CONFORMITY

Product Code:

3M41025/3

Description:

25A 3 Mod 4P MCB 10kA C Curve

**Intended Purpose:****Manufacturer:**

Proteus Switchgear. Stafford Park 12. Telford.
Shropshire. TF3 3BJ. United Kingdom.

Ratings & Characteristics:

Voltage Rating	400 V
Current Rating	25A
Frequency	50 Hz

Compliance:

Low Voltage Directive 2014/35/EU, Restriction of
the use of certain hazardous substances directive
2011/65/EU, Waste Electrical and Electronic
Equipment directive 2012/19/EU

Designated Standards:

BS EN 60898



I declare that the object of the declaration above is in conformity with the relevant harmonization legislation and national standards.

Signed for and on behalf of Proteus Switchgear

Date:

03/12/2025

Ian Down.
Business Manager.

Declaration of Conformity

PROTEUS