



Product Name: FESTOON KIT

General information

- This luminaire must be installed in accordance with the latest edition of the IET Wiring Regulations and local Building Regulation by a qualified competent person.
- The mains power supply must be turned off before inspection, installation or removal of the luminaire, ensuring that the supply is locked off to prevent inadvertently switching the supply on.
- It is the installer's responsibility to ensure that the installation is suitable for the total load of the luminaire(s). The supply cable fuses/circuit breakers must be correctly rated for the electrical load and taking into account for any transient inrush currents that may occur.
- It is the installer's responsibility to ensure that the environmental operating and storage conditions are complied with and that any fire risks are considered.
- Do not perform insulation strength or insulation resistance tests on the installation with the luminaire(s) connected, this can damage the luminaires and give erroneous readings.
- Do not loop-in supply cables at the luminaire supply terminals unless there is provision for 2-way connection at the terminals.
- Emergency lighting luminaires must be installed and maintained in accordance with the emergency lighting standard BS 5266-1.
- To ensure that the product warranty remains valid, the luminaire must be installed and maintained in accordance with these installation instructions and the product must not be modified in any way.

 Luminaires marked with this symbol must not be covered with thermally insulating material.
 This symbol on covers over light sources indicates dangerous live parts do not operate the luminaire with this cover removed.

Dimensions

| | A (mm) | B (mm) | C (mm) |
|------------|--------|--------|--------|
| TSFK100DLC | 22000 | 175 | 135 |


Technical Illustration for reference only.

The illustration shows a horizontal line representing the festoon cable with five luminaire icons spaced along it. Dimension A is the total length from the start of the cable to the end of the last luminaire. Dimension B is the vertical height from the cable to the top of the luminaire. Dimension C is the vertical height of the luminaire itself.









Page 1 of 2

Tamlite Technical
 Stafford Park 12,
 Telford, Shropshire,
 TF3 3BJ

+44(0)1952 292441
 technical@tamlite.co.uk
 Document No: V1



Product Name: FESTOON KIT

| | |
|--|---|
| <p>1</p>  <p>Suspend the product to desired location.</p> | <p>2</p>  <p>Place festoon guard over lamp holder.</p> |
| <p>3</p>  <p>Clip festoon guard on to yellow wire.</p> | <p>4</p>  <p>Screw in lamp provided.</p> |
| <p>5</p>  <p>For end of termination, screw end cap on to female end of wiring.</p> | <p>6</p>  <p>To add additional festoons, screw male end into female in correct orientation.</p> |
| <p>7</p>  <p>Do not exceed a maximum of 4 kits in series.</p> | <p>8</p>  <p>Connect supply plug to 110v transformer output socket.</p> |

Page 2 of 2

Tamlite Technical
Stafford Park 12,
Telford, Shropshire,
TF3 3BJ

+44(0)1952 292441
technical@tamlite.co.uk
Document No: V1

